

**SEWER CONNECTION PERMIT**  
*Sweetsir Farm, Sligo Road & Astilbe Lane Subdivisions*  
*Low Pressure Sewer Ultra Cav Pump Systems*  
*(or approved equal)*

**Type of Connection**

- ( ) Residential \$2,250.00  
( ) Commercial \$10.00 per gallon of flow      Tax Map      Lot #

**Contractor Requirements**

The contractor whom the homeowner eventually hires must:

1. Present the Town with a Certificate of Insurance in order to work in any Town Right of Way (\$300,000 minimum coverage).
2. Present the Town with the Dig-Safe Number for the project.
3. Obtain a Road Opening Permit from the Town Engineer.
4. Meet with the Town Engineer or Wastewater Superintendent to review material and installation requirements.

I have read and understand the above compliance requirements and will pass this information onto my contractor. All requirements must be met prior to issuing permit.

Contractor's Signature	or	Homeowner's Signature
Address		Address
Telephone		Telephone

If signed by a contractor, a homeowner's signature is not necessary; however, a copy will be mailed to the homeowner.

**YARMOUTH PUBLIC WORKS DEPARTMENT  
WASTEWATER DIVISION**

**Sewer Connection Permits/Installation Requirements**

- 1) All pipe to be schedule 40 PVC, SDR – 35, PVC or Ductile Iron no smaller than 4" in diameter.
- 2) Pipe shall be bedded in ¾" crushed stone to the property line and ¾" crushed stone or sand from the property line to the house. Stone shall be to the top of pipe. A layer of filter fabric shall be installed between the stone and sand. Min. 12" of sand on top of fabric, then existing material.
- 3) The pipe shall be laid at a slope of no less than 1/8" per foot pitch. All gravity sewer runs extending more than 90 feet in length, must have clean-outs installed every 90 feet.
- 4) All sewer lines with less than 3 ½' of cover shall be insulated by 2" of Blue board insulation. Two 1" sheets are not allowed.
- 5) **No pipe shall be back filled prior to inspection by the Yarmouth Wastewater Department or the Town Engineer. Any pipe back filled prior to inspection shall be in Non-Compliance with the Town Ordinances and shall be uncovered for inspection. No occupancy permit shall be issued without a sewer inspection.**
- 6) Inspections will cover the entire sewer line, from the connection to the main or manhole, back to the house.
- 7) **The Wastewater Division shall be given 24 hours notice on all inspections.**  
Office hours 7:00 AM to 2:00 PM Monday – Friday  
Telephone 846-2415
- 8) Pumps systems shall be approved by the Town Engineer and or the Supt. Of Pollution Control

Should you have any questions, please contact Mike Crosby, Water Pollution Control Supervisor at 846-2415 or Bill Shane, Public Works Administrator at 846-4971.

I have read and understand the above policy and will comply with each item.

\_\_\_\_\_  
Signature of Contractor Representative

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Address  
\_\_\_\_\_

